



SECTION
NOT TO SCALE

NOTES:

1. 8" PRV STATION SHOWN. 6" PRV STATION IS IDENTICAL EXCEPT THE UPSTREAM AND DOWNSTREAM PIPING, FITTINGS, AND VALVES ARE 6".
2. PAINT ALL EXPOSED PIPING AND FITTINGS WITHIN VAULT AND ABOVE GRADE.
3. ALL VALVES INSIDE VAULT TO HAVE HAND WHEEL OPERATORS.

APPROVED: SCOTT THOMASSON
REV. DATE: FEB. 1, 1997

WATER/WASTEWATER DIVISION



STANDARD DETAILS

**6" AND 8" PRV STATION
SECTION**

FILE SD709A.DWG DRAWING NO. **709A**